Douglas Ruggiano, P.E., P.A.

10059 SW 156th Avenue Miami, FL. 33196 786-210-0881

Reference: Product Certification Statement

Rooftop Mounted Mechanical Equipment Fujitsu Outdoor HVAC Unit (Group 2) Model Nos.: **AOU18RLB**; **AOU24RLB**

> AOU9RLFF; AOU12RLFF; AOU15RLFF AOU9RLFFH; AOU12RLFFH; AOU15RLFFH AOU9RLFC; AOU12RLFC; AOU18RLFC AOU9RLS3; AOU12RLS3; AOU15RLS3 AOU9RLS3H; AOU12RLS3H; AOU15RLS3H

Based on the manufacturers cut sheets for the referenced rooftop equipment, I have performed a wind load analysis to determine compliance with wind load criteria set forth by 2017 Florida Building Code Mechanical Section 301.15, Florida Building Code Building Chapter 16 and ASCE 7-10. Analysis results demonstrate that the equipment without retrofit is structurally adequate to withstand wind loads at the specified mounting heights for Exposure Categories identified in Table 1. This wind certification includes anchorage of equipment with 5/16" diameter anchors at the four base mount locations. Anchor material strength shall meet or exceed ASTM A307 requirements. Specifications for anchor attachment to host structure and certification for structural adequacy of host support structure is not included and shall be done by others. For analysis results, refer to Summary of Results at the end of the structures report associated with this certification.

	TABLE 1					
Design Wind Speed	Max Mounting Height Above Natural Grade (ft)					
Design wind speed	Exposure C	Exposure D	Kz			
120	500	500	3.05			
130	500	500	2.60			
140	500	500	2.24			
150	500	500	1.95			
160 425		275	1.72			
170	225	140	1.52			
175	180	100	1.43			
180	140	75	1.36			
186	105	50	1.27			
190	70	40	1.22			
200 50		20	1.10			

E PORID

Douglas J. Ruggiano, P.E.

Florida License No. 51497

WIND LOAD ANALYSIS AND STRUCTURAL CALCULATIONS

FOR

WIND CERTIFICATION

OF

ROOFTOP MECHANICAL EQUIPMENT

FUJITSU OUTDOOR HVAC UNIT (GROUP 2)

MODEL NOS:

AOU18RLB; AOU24RLB

AOU9RLFF; AOU12RLFF; AOU15RLFF

AOU9RLFFH; AOU12RLFFH; AOU15RLFFH

AOU9RLFC; AOU12RLFC; AOU18RLFC

AOU9RLS3; AOU12RLS3; AOU15RLS3

AOU9RLS3H; AOU12RLS3H; AOU15RLS3H



Prepared By:

Douglas J. Ruggiano, P.E. License No. 51497 10059 SW 156 Avenue Miami, FL. 33196 786-210-0881

AUGUST 2020

Wind Load Analysis for Rooftop Mounted Equipment

Equipment:

Fujitsu 0.75 - 2.0 Ton Chassis

Model Nos: AOU18RLB; AOU24RLB;

AOU9RLFF; AOU12RLFF; AOU15RLFF; AOU9RLFFH; AOU12RLFFH; AOU15RLFFH; AOU9RLFC; AOU12RLFC; AOU18RLFC AOU9RLS3; AOU12RLS3; AOU15RLS3 AOU9RLS3H; AOU12RLS3H; AOU15RLS3H

Approximate Weight of Unit (wt_{unit}): $wt_{unit} := 86 \cdot lbf$

Length of Unit (L_e): $L_e := 31.1 \cdot in$

Width of Unit (W_e): $W_e := 11.3 \cdot in$

Height of Unit (H_e): $H_e := 24.4 \cdot in$

Mount Hole spacing Along Length (MH_L): $MH_L := 21.3 \cdot in$

Mount Hole spacing Along Width (MH_W): $MH_W := 12.5 \cdot in$

Comer Weight at Point A (Rdl_A): $Rdl_A := \frac{wt_{unit}}{4}$ $Rdl_A = 21.5 \cdot lbf$

Comer Weight at Point B (Rdl_B): $Rdl_{B} := \frac{wt_{unit}}{4}$ $Rdl_{B} = 21.5 \cdot lbf$

Comer Weight at Point C (Rdl_C): $Rdl_{C} := \frac{wt_{unit}}{4}$ $Rdl_{C} = 21.5 \cdot lbf$

Comer Weight at Point D (Rdl_D): $Rdl_{D} := \frac{wt_{unit}}{4}$ $Rdl_{D} = 21.5 \cdot lbf$

Material Data:

Ultimate Tensile Strength of Cold Formed

Fu1_{case} := 45·ksi
Sheet Metal Casing in Contact with Screw

Head (Fu1_{cas}):

Ultimate Tensile Strength of Cold Formed

Fu2_{case} := 45·ksi
Sheet Metal Casing Not in Contact with Screw

Head (Fu2cas):

Ultimate Strength of Metal Fasteners (Fu_{fas}): $Fu_{fas} := 50 \cdot ksi$

Calculate Wind Load (Per ASCE 7-10)

Building Risk Category (B_{Risk}): $Bldg_{Risk} := "IV"$

Design Wind Speed (V): V := 186 mph

Mounting Height above Grade (H): $H := 50 \cdot ft$

ExpCat := "D"

Velocity pressure exposure coefficient at height from ground to $K_z := 1.27$

Centroid of Equipment (K_z):

Topographic Factor (K_{zt}): $K_{zt} := 1.0$

Directionality Factor From Table 6-4 (Similar Structures) (K_d): $K_d := 0.90$

Ultimate Design Velocity Pressure Evaluated at height z of the Centroid of the Effective Area (q_{z I II T}):

$$q_{zULT} := 0.00256 \cdot K_z \cdot K_{zt} \cdot K_{d} \cdot V^2 \cdot psf$$

$$q_{zULT} = 101.2 \cdot psf$$

Allowable Design Velocity Pressure Evaluated at height z of the Centroid of the Effective Area (qz):

$$\mathbf{q}_{\mathbf{z}} \coloneqq \mathbf{q}_{\mathbf{z}\mathbf{ULT}} \cdot 0.6 \qquad \qquad \mathbf{q}_{\mathbf{z}} = 60.7 \cdot \mathbf{psf}$$

Lateral Pressure Coefficient
$$GCf_{lat} := 1.9$$

Uplift Pressure Coefficent
$$GCf_{upl} := 1.5$$

Lateral Wind Pressure (
$$p_{lat}$$
): $p_{lat} := q_z \cdot GCf_{lat}$ $p_{lat} = 115.4 \cdot psf$

$$\text{Uplift Wind Pressure } (p_{upl}) \text{:} \qquad \qquad p_{upl} \coloneqq q_z \cdot GCf_{upl} \qquad \qquad p_{upl} = 91.1 \cdot psf$$

Projected Area Normal to Wind (A_n):
$$A_n := L_e \cdot H_e$$
 $A_n = 5.3 \cdot \text{ft}^2$

Projected Area Parallel to Wind (Ap):
$$A_p := L_e \cdot W_e \qquad \qquad A_p = 2.4 \cdot \mathrm{ft}^2$$

Calculate the Wind Load Reactions at Unit to Curb (Refer to Figure I)

$$F_h := p_{lat} \cdot A_n$$
 $F_h = 0.6 \cdot kip$

$$F_{up} \coloneqq p_{upl} \cdot A_p \qquad \qquad F_{up} = 0.2 \cdot kip$$

$$\mathrm{Rwl}_{A} \coloneqq \frac{F_{h} \cdot \frac{H_{e}}{2}}{2 \cdot \mathrm{MH}_{W}} - \frac{F_{up}}{4}$$

$$\mathrm{Rwl}_{A} = 0.2 \cdot \mathrm{kip} \quad \text{(Downward)}$$

$$Rwl_{B} := \frac{F_{h} \cdot \frac{H_{e}}{2}}{2 \cdot MH_{W}} - \frac{F_{up}}{4}$$

$$Rwl_{B} = 0.2 \cdot kip \quad \textbf{(Downward)}$$

$$\mathrm{Rwl}_{C} \coloneqq \frac{F_{h} \cdot \frac{H_{e}}{2}}{2 \cdot \mathrm{MH}_{W}} + \frac{F_{up}}{4}$$

$$\mathrm{Rwl}_{C} = 0.4 \cdot \mathrm{kip} \quad \text{(Upward)}$$

$$Rwl_{D} := \frac{F_{h} \cdot \frac{H_{e}}{2}}{2 \cdot MH_{W}} + \frac{F_{up}}{4}$$

$$Rwl_{D} = 0.4 \cdot kip \quad \text{(Upward)}$$

Calculate Combined Reactions at each Anchorage Location (Dead+Windx FSstab):

Vertical Reactions:

$Rtot_{A} := Rdl_{A} + Rwl_{A}$	$Rtot_{A} = 0.3 \cdot kip$
---------------------------------	----------------------------

Horizontal Reactions:

$$R_{hor} := \frac{F_h}{4}$$
 $R_{hor} = 0.2 \cdot kip$

Therefore, with the assumption of 4 anchor points (1 at each corner of the unit); each anchorage to curb and corresponding building support components must be designed to withstand the Uplift Reaction of $R_{tot} = -0.3 \cdot kip$ and a Horizontal Shear Reaction of $R_{hor} = 0.2 \cdot kip$.




FIGURE I

Calculate No. of Fasteners Req'd for Panel No. 1

Attachment Data:

Nominal Screw Diameter (Φ_{screw}):

 $\phi_{\text{screw}} := 0.157 \cdot \text{in}$

Thread Series, threads per in (unc):

unc := 14

Affective Shear Stress Area of Screw (A_v):

$$A_{V} := \frac{\pi}{4} \cdot \left(\frac{\Phi_{screw}}{in} - \frac{1.2269}{unc} \right)^{2} \cdot in^{2}$$

$$A_{V} = 0.0038 \cdot in^2$$

Thickness of Metal Casing in Contact with Screw Head (t1):

 $t1 := 0.0236 \cdot in$

Thickness of Metal Casing Not in Contact with Screw Head (t2):

 $t2 := 0.0236 \cdot in$

Casing Thickness Ratio (rc):

$$rc := \frac{t2}{t1}$$

$$rc = 1$$

Panel Length (Lpan):

$$L_{pan} := L_e = 31.1 \cdot in$$

Panel Width (W_{pan}):

$$W_{pan} := W_e = 11.3 \cdot in$$

Calculate Nominal Shear per Fastener Based on Bearing for $rc \le 1.0$ (Pns_{case}):

$$Pns1 := 4.2 \cdot \sqrt{t1^3 \cdot \phi_{screw}} \cdot Fu1_{case}$$

$$Pns1 = 0.272 \cdot kip$$

$$Pns2 := 2.7 \cdot t1 \cdot \phi_{screw} \cdot Fu1_{case}$$

$$Pns2 = 0.450 \cdot kip$$

$$Pns3 := 2.7 \cdot t2 \cdot \phi_{screw} \cdot Fu2_{case}$$

$$Pns2 = 0.450 \cdot kip$$

$$Pns_{\color{red} case} := if(Pns1 \leq Pns2, if(Pns1 \leq Pns3, Pns1, Pns3), if(Pns2 \leq Pns3, Pns2, Pns3))$$

$$Pns_{case} = 0.272 \cdot kip$$

Calculate Nominal Shear per Fastener Based on Shear Capacity of Screw (Pns_{screw}):

$$Pns_{screw} := Fu_{fas} \cdot A_{v}$$

$$Pns_{screw} = 0.189 \cdot kip$$

Calculate Allowable Shear per Fastener (Pas):

$$\Omega_{\mathrm{brg}} := 3.0$$

$$Pas1 := \frac{Pns_{case}}{\Omega_{brg}}$$

$$Pas1 = 0.091 \cdot kip$$

$$\Omega_{\text{screw}} := \frac{\sqrt{3}}{0.40}$$

$$Pas2 := \frac{Pns_{screw}}{\Omega_{screw}}$$

$$Pas2 = 0.044 \cdot kip$$

$$Pas := if(Pas1 \le Pas2, Pas1, Pas2)$$

$$Pas = 0.044 \cdot kip$$

Calculate Total Uplift on Panel (F_{upl}) :

$$F_{upl} := p_{upl} \cdot L_{pan} \cdot W_{pan}$$

$$F_{upl} = 0.2 \cdot kip$$

Calculate Total No. of Screws Required (No_{screws}):

$$No_{screws1} := ceil \left(\frac{F_{upl}}{Pas} \right)$$

$$No_{screws1} = 6$$

Calculate No. of Fasteners Req'd for Panel No. 2

Attachment Data:

Nominal Screw Diameter (Φ_{screw}):

 $\phi_{\text{screw}} := 0.157 \cdot \text{in}$

Dia of Hex Head:

 $\phi_{head} := 0.42 \cdot in$

Thread Series, threads per in (unc):

unc := 14

Affective Tensile Stress Area of Screw (At):

$$A_t := \frac{\pi}{4} \cdot \left(\frac{\varphi_{screw}}{in} - \frac{0.9743}{unc} \right)^2 \cdot in^2$$

 $A_t = 0.006 \cdot in^2$

Thickness of Metal Casing in Contact with Screw Head (t1):

 $t1 := 0.0236 \cdot in$

Thickness of Metal Casing Not in Contact with Screw Head (t2):

 $t2 := 0.0236 \cdot in$

Casing Thickness Ratio (rc):

$$rc := \frac{t2}{t1}$$

rc = 1

Panel Length (Lpan):

 $L_{pan} := H_e = 24.4 \cdot in$

Panel Width (W_{pan}):

 $W_{pan} := W_e = 11.3 \cdot in$

Calculate Nominal Tension or Pullout per Fastener Based on Bearing (Pnt_{case}):

 $Pnt1 := 0.85 \cdot t2 \cdot \phi_{screw} \cdot Fu2_{case}$

 $Pnt1 = 0.142 \cdot kip$

 $Pnt2 := 1.5 \cdot t1 \cdot \phi_{head} \cdot Fu1_{case}$

 $Pnt2 = 0.669 \cdot kip$

 $Pnt_{case} := if(Pnt1 \le Pnt2, Pnt1, Pnt2)$

 $Pnt_{case} = 0.142 \cdot kip$

Calculate Nominal Tensile or Pullout per Fastener Based on Tensile Capacity of Screw (Pnt_{screw}):

 $Pnt_{screw} := Fu_{fas} \cdot A_t$

 $Pnt_{screw} = 0.300 \cdot kip$

Calculate Allowable Pullout per Fastener (Pat):

$$\Omega_{\rm brg} := 3.0$$

$$Pat1 := \frac{Pnt_{case}}{\Omega_{brg}}$$

$$Pat1 = 0.047 \cdot kip$$

$$\Omega_{\text{screw}} := \frac{1}{0.40}$$

$$Pat2 := \frac{Pnt_{screw}}{\Omega_{screw}}$$

$$Pat2 = 0.120 \cdot kip$$

 $Pat := if(Pat1 \le Pat2, Pat1, Pat2)$

 $Pat = 0.047 \cdot kip$

Calculate Total Horizontal Force on Panel (F_{horiz}):

$$F_{horiz} := p_{lat} \cdot L_{pan} \cdot W_{pan}$$

 $F_{\text{horiz}} = 0.221 \cdot \text{kip}$

Calculate Total No. of Screws Required (No_{screws}):

$$No_{screws2} := ceil \left(\frac{F_{horiz}}{Pat} \right)$$

 $No_{screws2} = 5$

Calculate No. of Fasteners Req'd for Panel No. 3

Attachment Data:

Nominal Screw Diameter (Φ_{screw}):

 $\phi_{\text{screw}} := 0.157 \cdot \text{in}$

Dia of Hex Head:

 $\phi_{\text{head}} := 0.42 \cdot \text{in}$

Thread Series, threads per in (unc):

unc := 14

Affective Tensile Stress Area of Screw (At):

$$A_{t} := \frac{\pi}{4} \cdot \left(\frac{\phi_{screw}}{in} - \frac{0.9743}{unc} \right)^{2} \cdot in^{2}$$

 $A_t = 0.006 \cdot in^2$

Thickness of Metal Casing in Contact with Screw Head (t1):

t1 := 0.0236·in

Thickness of Metal Casing Not in Contact with Screw Head (t2):

 $t2 := 0.0236 \cdot in$

Casing Thickness Ratio (rc):

$$rc := \frac{t2}{t1}$$

$$rc = 1$$

Panel Length (L_{pan}):

$$L_{pan} := L_e = 31.1 \cdot in$$

Panel Width (W_{pan}):

$$W_{pan} := H_e = 24.4 \cdot in$$

Calculate Nominal Tension or Pullout per Fastener Based on Bearing (Pnt_{case}):

 $Pnt1 := 0.85 \cdot t2 \cdot \phi_{screw} \cdot Fu2_{case}$

 $Pnt1 = 0.142 \cdot kip$

 $Pnt2 := 1.5 \cdot t1 \cdot \phi_{head} \cdot Fu1_{case}$

 $Pnt2 = 0.669 \cdot kip$

 $Pnt_{case} := if(Pnt1 \le Pnt2, Pnt1, Pnt2)$

 $Pnt_{case} = 0.142 \cdot kip$

Calculate Nominal Tensile or Pullout per Fastener Based on Tensile Capacity of Screw (Pnt_{screw}):

 $Pnt_{screw} := Fu_{fas} \cdot A_t$

 $Pnt_{screw} = 0.300 \cdot kip$

Calculate Allowable Pullout per Fastener (Pat):

$$\Omega_{\rm brg} := 3.0$$

$$Pat1 := \frac{Pnt_{case}}{\Omega_{brg}}$$

$$Pat1 = 0.047 \cdot kip$$

$$\Omega_{\text{screw}} := \frac{1}{0.40}$$

$$Pat2 := \frac{Pnt_{screw}}{\Omega_{screw}}$$

$$Pat2 = 0.120 \cdot kip$$

 $Pat := if(Pat1 \le Pat2, Pat1, Pat2)$

$$Pat = 0.047 \cdot kip$$

Calculate Total Horizontal Force on Panel (F_{horiz}):

%open := 50%

$$F_{\text{horiz}} := p_{\text{lat}} \cdot L_{\text{pan}} \cdot W_{\text{pan}} \cdot (1 - \% \text{open})$$

$$F_{\text{horiz}} = 0.304 \cdot \text{kip}$$

Calculate Total No. of Screws Required (No_{screws}):

$$No_{screws3} := ceil \left(\frac{F_{horiz}}{Pat} \right)$$

$$No_{screws3} = 7$$

Check Adequacy of Base Plate and Anchorage Hardware

Attachment Data:

Nominal Bolt Diameter (Φ_{bolt}):

 $\phi_{bolt} := 0.3125 \cdot in$

Affective Bolt Area (Aeff):

$$A_{eff} := \frac{\pi}{4} \cdot \left(\frac{\varphi_{bolt}}{in}\right)^2 \cdot in^2$$

$$A_{eff} = 0.077 \cdot in^2$$

BoltMaterial := "ASTM A307 or Greater"

Allowable Tensile Strength (F_t):

 $F_t := 20 \cdot ksi$

Allowable Shear Strength (F_v):

 $F_{v} := 9.9 \cdot ksi$

Bolt Shear Capacity (Vall):

 $V_{all} := A_{eff} \cdot F_{v} = 0.8 \cdot kip$

Bolt Tension Capacity (T_{all}):

 $T_{all} := A_{eff} \cdot F_t = 1.5 \cdot kip$

Check Bolt Adequacy with Wind Perpendicular to Long Side

Number of Bolts Provided to resist Tension (NoBolts $_{\mbox{\footnotesize providens}}$):

 $NoBolts_{provtens} := 2$

$$t_{bolt} := \frac{\left| 2Rtot_{C} \right|}{NoBolts_{provtens}}$$

$$t_{bolt} = 0.3 \cdot kip$$

Number of Bolts Provided to resist Shear (NoBolts $_{\mbox{\footnotesize provdshear}}$):

NoBolts_{provshear} := 4

$$v_{bolt} \coloneqq \frac{2 \cdot R_{hor}}{NoBolts_{provshear}}$$

$$v_{bolt} = 0.1 \cdot kip$$

$$CSR_{bolt} := \frac{t_{bolt}}{T_{all}} + \frac{v_{bolt}}{V_{all}}$$

$$CSR_{bolt} = 0.316$$

 $Check_{bolt} := if(CSR_{bolt} \le 1.0, "OK", "NG")$

 $Check_{bolt} = "OK"$

Check Base Plate

Width of Base Plate:

 $b_{bp} := 2.2 \cdot in$

Thickness of Base Plate:

 $t_{bp} := 0.032 \cdot in$

Moment Arm:

arm := 1.5in

	Calculate Effective Section Properties of Base Plate (Unit - Inches)													
b	t	hflange	l1	12	d1	d2	A1	A2	ybar	у1	у2	Itotal	Stotal	Atotal
2.2	0.032	0.66	6.01E-06	0.000660	0.644	0.314	0.0704	0.0201	0.64	0.02	0.64	0.032506	0.050755	0.090496

Area:

Section Modulus:

Bending Stress:

Shear Stress:

Allowable Bending Stress

Allowable Shear Stress

$$CSR_{bp} := \frac{f_b}{F_b} + \left(\frac{f_v}{F_v}\right)^2 = 0.6$$

CheckBasePlate := $if(CSR_{bp} \le 1.0, "OK", "NG") = "OK"$

Summary of Results:

 $BuildingRisk := Bldg_{Risk} = "IV"$

DesignWindSpeed := $V \cdot mph = 186 \cdot mph$

ExposureCategory := ExpCat = "D"

MountingHeight := $H = 50 \cdot ft$

Number of Panel Fasteners Provided By Manufacturer:

Panel No. 1: $No_{screws.std1} := 6$

 $No_{screws std2} := 9$ Panel No. 2:

 $No_{screws std3} := 8$ Panel No. 3:

 $Ax := 0.090496 \cdot in^2$

 $Sx := 0.050755 \cdot in^3$

 $f_b := \frac{t_{bolt} \cdot arm}{S_x} = 9.8 \cdot ksi$

 $f_{V} := \frac{t_{bolt}}{A_{X}} = 3.7 \cdot ksi$

 $F_b := 0.6 \cdot F_v = 18000 \text{ psi}$

 $F_{V} := 0.4 \cdot F_{V} = 12000 \text{ psi}$

Number of Panel Fasteners Required By Analysis:

Panel No. 1:

 $No_{screws1} = 6$

 $No_{screws2} = 5$ Panel No. 2:

Panel No. 3: $No_{screws3} = 7$

Panel Fastening Check:

 $check_{panel1} := if \Big(No_{screws.std1} \geq No_{screws1}, "OK" \ , "NG" \ \Big) = "OK"$

 $\mathsf{check}_{panel2} \coloneqq \mathsf{if} \Big(\mathsf{No}_{\mathsf{screws}.\mathsf{std2}} \geq \mathsf{No}_{\mathsf{screws2}}, \mathsf{"OK"} \;, \mathsf{"NG"} \, \Big) = \mathsf{"OK"}$

 $check_{panel3} := if(No_{screws,std3} \ge No_{screws3}, "OK", "NG") = "OK"$

Equipment Tie Down to Support By Others:

BoltMaterial = "ASTM A307 or Greater"

TieDownBoltDia := $\phi_{bolt} = 0.3125 \cdot in$

 $CSR_{bolt} = 0.3$

 $CSR_{bp} = 0.6$